



W:CT

CITY OF HOUSTON

Post Office Box 1562 Houston, Texas 77251

Kathryn J. Whitmire, Mayor

CITY COUNCIL MEMBERS: Larry McKaskle • Ernest McGowan, Sr. • George Greanias • Rodney Ellis • Frank O. Mancuso • John G. Gooch • Christin Hartung
Dale M. Gorkzynski • Ben T. Reyes • Jim Westmoreland • Eleanor Tinsley • Jim Greenwood • Anthony W. Hall, Jr. • Judson Robinson, Jr. • CITY CONTROLLER: Lance Lator

April 24, 1986

RECEIVED

APR 29 1986

Mr. William R. Tobin, P.E.
Project Manager
McBride-Ratcliff and Associates, Inc.
7220 Langtry
Houston, Texas 77040

Re: Request for Wastewater Discharge Permit
Koppers South Cavalcade Site, Houston

Dear Mr. Tobin:

This letter is in response to your request for approval of a temporary wastewater discharge permit for the South Cavalcade Site, near 2000 Cavalcade Street.

Before the City of Houston can consider granting approval, the following information must be submitted to our office:

- (1) The legal name, name of owner or corporation head and mailing address of the company responsible for clean up of the site.
- (2) An alternative method of disposal for the wastewater to be discharged, should the results of the analyses not be acceptable to the City.

To assure proper disposal of the wastewater, the City is also requiring that the following preventative measures be taken:

- (1) An additional holding tank must be used and a spill prevention control and counter measure plan must be formulated.
- (2) Two (2) holding tanks must be equipped with liquid level indicators.

002419

037

Mr. William R. Tobin, P.E.

April 24, 1986

Page 2

When these actions are complete and the requested information has been submitted, the temporary permit for discharge will be issued. A sample must be taken from each tank prior to discharge and analyzed for priority pollutant base/neutrals and acids organics. The results of the sample analysis must be called in or mailed to the Industrial Waste Section to obtain approval before each discharge.

Should you have any questions, please contact Dr. M.T. Garrett at 630-6049.

Sincerely,



C.J. Smith, P.E.
Deputy of Utility Operations
Department of Public Works

CJS:VS:rk
cc: Dr. M.T. Garrett
Lorenzo Alonzo
Vicky Sanchez

002420